

EXHIBIT E

From: webmaster@cpuc.ca.gov <webmaster@cpuc.ca.gov>

Sent: Thursday, November 8, 2018 4:09:50 PM

To: usrb@cpuc.ca.gov

Cc: Allen, Meredith

Subject: Electric Safety Incident Reported- Pacific Gas & Electric Incident No: 181108-9002

The Following information regarding this incident has been reported:

Reporting Date: 11/8/2018 6:06:53 PM

Incident Date: 11/8/2018 @ 6:15 a.m.

Reported By: Meredith Allen, Sr. Director - Regulatory Relations

Utility Name: Pacific Gas & Electric

Phone Number: (415)828-5765

Email Address: MEAE@pge.com

Incident Location: Pulga Rd. Pulga,, Butte County

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? Yes
- Media Coverage? No

Cause of Incident: Unknown (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Caribou-Palermo
- Voltage (KV): 115kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: On November 8, 2018, at approximately 0615 hours, PG&E experienced an outage on the Caribou-Palermo 115 kV Transmission line in Butte County. In the afternoon of November 8, PG&E observed by aerial patrol damage to a transmission tower on the Caribou-Palermo 115 kV Transmission line, approximately one mile north-east of the town of Pulga, in the area of the Camp Fire. This information is preliminary.